

105.2 .13 Work exempt from permit. Nonfixed and moveable fixtures, racks, cases, counters and partitions not over 5'-9" in ht.

§1002 Definitions

§1002.1

Aisle – An exit access component that defines and provides a path of egress travel.

Aisle Accessway – That portion of an exit access that leads to an aisle.

Common Path of Egress Travel – That portion of exit access that the occupants are required to traverse before 2 separate and distinct paths of egress travel are available.

Corridor – An enclosed exit access component that defines and provides a path of egress travel to an exit. §1017.2 Min wth is 44"

Exit Access – That portion of a means of egress system that leads from any occupied portion of a building or structure to an exit.

Means of Egress - A continuous and unobstructed path of vertical and horizontal egress travel from any occupied portion of a building or structure to a public way. A means of egress consists of 3 separate and distinct parts: The exit access, the exit and the exit discharge.

§1014 Exit Access

§1014.2 Egress through intervening spaces – Egress from a room or space shall not pass through adjoining or intervening rooms or areas, except where such adjoining rooms or areas are accessory to the area served, are not high hazard occupancy and provide a discernable path of egress travel to an exit.

§1014.3 Common path or egress travel – May not exceed 75', except in Group B, F and S occupancies shall not be more than 100' provided that the building is equipped with an automatic fire sprinkler system.

§1014.4 Aisles - Aisles shall be provided from all occupied portions of the exit access which contain seats, tables, furnishings, displays and similar fixtures.

§1014.4.1 Aisles in Group B and M occupancies, the clear width shall be determined by §1005.1 for the occupant load served, but shall not be less than 36", except nonpublic aisles serving less than 50 people and are not required to be accessible need not exceed 28" in width.

§1014.4.2 Aisle accessways in Group M – An aisle accessway shall be provided on at least one side of each element within a merchandise pad. Min. width is 30" when not required to be accessible. Common Path of Egress Travel shall not exceed 30'.

§1014.4.3 Seating at tables – Where seating is located at a table or counter and is adjacent to an aisle or **aisle accessway**, the measurement of required clear width of the aisle or aisle accessway shall be made to a line 19" away from and parallel to the edge of the table or counter.

1014.4.3.2 Table and seating accessway width – **Aisle accessways** shall provide a minimum of 12" of width plus 0.5" of width for each additional foot, or fraction thereof, beyond 12' of aisle accessway length measured from the center of the seat farthest from an aisle. **Exception:** Portions of an aisle accessway having a length not exceeding 6' and used by a total of not more than four persons.

§1025 Assembly – Provisions apply to Occupancies in Group A which contain seats, tables, displays & equipment. Does not apply to Group B accessory areas with tables and chairs that are also classified as assembly when the occupant load is under 50.

TOP TEN EXITING REQUIREMENTS

1003.6 Continuity The path of egress travel along a means of egress shall not be interrupted by any building element other than a means of egress component specified in Chapter 10.

1005.1 Egress width The means of egress width shall not be less than required by this section.

1017.2a Corridors min 44"

1014.4.3.2 Aisle min 36"

1008.1.1a Doors min 32" clear opening

1025.9.1 Minimum egress width or greater for Assembly occupancies.

1007.1 Accessible Means of Egress Each accessible portion of a space must be served by an accessible means of egress. If more than one means of egress is required, not less than 2 must be served by an accessible means of egress.

1015.1 Two or more exits Spaces which exceed and occupant load of 49, or a common path of travel of 75' (w/o fs) or 100' (w/fs), must have 2 exits or exit access doorways.

1014.3 Common Path of Travel Common path of egress travel may no exceed 75' (w/o fs) or 100' (w/fs).

1017.3 Dead Ends Where more than 1 exit is required, exit access shall be arranged so that there are no dead end corridors exceeding 20' (w/o fs) or 50' (w/fs). Dead ends not limited if corridor length is 2.5 times the least width of the space.

1016.1 Exit Arrangement Where 2 exits or exit access doorways are required, exit doors shall be located ½ the maximum overall diagonal distance of the space apart or ⅓ the overall diagonal distance apart (w/fs).

1016.1 Travel Distance The max travel distance from any point in a building to an exit shall not exceed 200' (w/o fs) or 300' (w/fs).

1014.2 Intervening Spaces Egress from a room or space shall not pass through intervening rooms or spaces except when they are accessory to the area served, are not a high hazard and provide a discernable path to an exit. Egress shall not pass through kitchens, storage rooms, closets or spaces used for similar purposes.

1011.5.1 Exit Signs Exit doors and exit access doors shall be marked with an illuminated sign.